


Reaction to fire



The applicant: **KRYPTON CHEMICAL**
Martí i Franqués, 12, P.I. Les Tapies
ES-43890 Vandellòs i Hospitalet Infant
Tarragona

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2022AN0865



aitex
textile research institute

CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

N° 22AN0865

The sample reference:

“ Rayston Fire E”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s2,d0”

Alcoy, February 27th 2019.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.